

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1492:100 Page 1 of 1

CATEGORY: Control Units (Non High Rise)

LISTEE: Northern Computers Inc., 5007 S. Howell ave., Milwaukee, WI 53207
Contact: William Bryar (800) 323-4576 ext 4309

DESIGN: Model N-750 fire alarm control unit. Inherently power-limited, automatic, manual, waterflow, sprinkler supervisory, local and central station service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

N-750	Control Unit Assembly
N-750-ZONE	Zone Expander
N-750-PI	Serial-Parallel Interface
N-750-SDB	Input/Output Module
N-750-PAIT	Keypad
4875	Dual Phone Line Monitor
7628	EOL Resistor
9227	Transformer
4890	Enclosure
4195	Auxiliary Power Supply
4165	Transformer Cover
4884	Supervised Bell Module
N-750-ADM	Access Control Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

NOTE:

1. For the Alarm Verification Feature, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.
2. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.

XLF: 7165-0559:131

*Reinstated 12-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager